

**Certifikat
o nespremenljivosti lastnosti****REG2-0004-03 – ZGPro1 – 2230**

Na podlagi Zakona o gradbenih proizvodih - ZGPro-1 se ta certifikat nanaša na gradbeni proizvod

Dvokrilna kovinska požarna vrata SPLIT 2B 60

ki ga

DIERRE S.p.A.,**Strada Statale per Chieri 66/15, 14019 Villanova d'Asti, Italija,**

proizvaja v obratu

DIERRE S.p.A.,**Strada della Varletta 21, 14019 Villanova d'Asti, Italija.**

Ta certifikat potrjuje, da so bila upoštevana vsa določila glede ocenjevanja in preverjanja nespremenljivosti lastnosti, opisana v Slovenskem Tehničnem Soglasju

STS-08/012, z veljavnostjo od 30. 1. 2023 do 29. 1. 2028

po sistemu 1 in da

proizvod izpolnjuje vse zgoraj predpisane zahteve.

Za podrobnejše informacije v zvezi z lastnostmi proizvoda se uporablja zgoraj navedeni STS.

Ta certifikat je bil prvič izdan **15. 11. 2013** in ostaja v veljavi do **29. 1. 2028** oziroma toliko časa, dokler se ne spremenijo preskusne metode in/ali zahteve glede tovarniške kontrole proizvodnje, določene v zgoraj navedenem STS, ki se uporabljajo pri ocenjevanju lastnosti in deklariranih značilnosti, oziroma dokler se bistveno ne spremeni proizvod ali pogoji proizvodnje v obratu, razen če ga določeni organ za certificiranje proizvoda začasno ali trajno prekliče.

Natančnejši podatki glede obsega proizvoda so podani v prilogi tega certifikata.

Ljubljana, 15. 3. 2023

Pooblaščen podpisnik certifikacijskega organa:

Marjan Japelj, univ.dipl.fiz.



Certifikat zajema naslednji obseg proizvoda:

Vrsta proizvoda	Lastnost	Vrednost	Predvidena uporaba proizvoda
Dvokrilna kovinska požarna vrata SPLIT 2B 60	Požarna odpornost	El ₂ 60	Za vgradnjo na mejo požarnih sektorjev, za vgradnjo na evakuacijskih poteh
	Evakuacija	Ustreza	

konec Priloge



ZAVOD ZA
GRADBENIŠTVO
SLOVENIJE

SLOVENIAN
NATIONAL BUILDING
AND CIVIL ENGINEERING
INSTITUTE

Dirničeva ulica 12
1000 Ljubljana
Slovenija

info@zag.si
www.zag.si

Designated certification body

Certificate of constancy of performance

REG2-0004-03 – ZGPro1 – 2230

(English translation from 15. 3. 2023, the original version is in Slovenian)

On the basis of the Law on Construction Products - ZGPro-1 this certificate applies to the construction product

Double leaf steel fire door SPLIT 2B 60

produced by

DIERRE S.p.A.,

Strada Statale per Chieri 66/15, 14019 Villanova d'Asti, Italy

in the manufacturing plant

DIERRE S.p.A.,

Strada della Varletta 21, 14019 Villanova d'Asti, Italy.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the Slovenian Technical Approval

STS-08/012, valid from 30. 1. 2022 to 29. 1. 2028

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

For detailed information about the performance characteristics of the product the above-mentioned STS itself should be consulted.

This certificate was first issued on **15. 11. 2013** and will remain valid until **29. 1. 2028** as long as the test methods and/or factory production control requirements included in the STS, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the designated product certification body.

Detailed information about the scope of the product is given in the annex to this certificate.

Ljubljana, 15. 3. 2023

Authorised signatory of the Certification body:

Marjan Japelj, B. Sc.

Scope of the certificate:

Product name	Characteristics	Value	Intended use
Double leaf steel fire door SPLIT 2B 60	Fire resistance	EL ₂ 60	For fire compartmentation, for use on escape routes
	Escape routs	Confirms	

End of the Annex
