

## **Certifikat o nespremenljivosti lastnosti**

**REG2-0004-03 – ZGPro1 – 2438**

Na podlagi Zakona o gradbenih proizvodih - ZGPro-1 se ta certifikat nanaša na gradbeni proizvod

**Dvokrilna kovinska požarna vrata IDRA 2B 120**

ki ga

**DIERRE S.p.A.,**

**Strada Statale per Chieri 66/15, 14019 Villanova d'Asti, Italija,**

proizvaja v obratu

**DIERRE S.p.A.,**

**Strada della Varletta 21, 14019 Villanova d'Asti, Italija.**

Ta certifikat potrjuje, da so bila upoštevana vsa določila glede ocenjevanja in preverjanja nespremenljivosti lastnosti, opisana v Slovenskem Tehničnem Soglasju

**STS-07/110, z veljavnostjo od 21. 12. 2022 do 20. 12. 2027**

po sistemu 1 in da

**proizvod izpolnjuje vse zgoraj predpisane zahteve.**

Za podrobnejše informacije v zvezi z lastnostmi proizvoda se uporablja zgoraj navedeni STS.

Ta certifikat je bil prvič izdan **22. 12. 2014** in ostaja v veljavi do **20. 12. 2027** oziroma toliko časa, dokler se ne spremenijo preskusne metode in/ali zahteve glede tovarniške kontrole proizvodnje, določene v zgoraj navedenem STS, ki se uporabljajo pri ocenjevanju lastnosti in deklariranih značilnosti, oziroma dokler se bistveno ne spremeni proizvod ali pogoji proizvodnje v obratu, razen če ga določeni organ za certificiranje proizvoda začasno ali trajno prekliče.

Natančnejši podatki glede obsega proizvoda so podani v prilogi tega certifikata.

Ljubljana, 15. 3. 2023

**Pooblaščen podpisnik certifikacijskega organa:**

Marjan Japelj, univ.dipl.fiz.



Certifikat zajema naslednji obseg proizvoda:

| Vrsta proizvoda                                    | Lastnost          | Vrednost                         | Predvidena uporaba proizvoda                                                            |
|----------------------------------------------------|-------------------|----------------------------------|-----------------------------------------------------------------------------------------|
| Dvokrilna kovinska<br>požarna vrata<br>IDRA 2B 120 | Požarna odpornost | El <sub>2</sub> 120              | Za vgradnjo na mejo požarnih/dimnih<br>sektorjev, za vgradnjo na evakuacijskih<br>poteh |
|                                                    | Dimotesnost       | S <sub>a</sub> /S <sub>200</sub> |                                                                                         |
|                                                    | Evakuacija        | Ustreza                          |                                                                                         |

konec Priloge

## Certificate of constancy of performance

**REG2-0004-03 – ZGPro1 – 2438**

(English translation from 15. 3. 2023, the original version is in Slovenian)

On the basis of the Law on Construction Products - ZGPro-1 this certificate applies to the construction product

**Double leaf steel fire door IDRA 2B 120**

produced by

**DIERRE S.p.A.,**

**Strada Statale per Chieri 66/15, 14019 Villanova d'Asti, Italy**

in the manufacturing plant

**DIERRE S.p.A.,**

**Strada della Varletta 21, 14019 Villanova d'Asti, Italy.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the Slovenian Technical Approval

**STS-07/110, valid from 21. 12. 2022 to 20. 12. 2027**

under system 1 are applied and that

**the product fulfils all the prescribed requirements set out above.**

For detailed information about the performance characteristics of the product the above-mentioned STS itself should be consulted.

This certificate was first issued on **22. 12. 2014** and will remain valid until **20. 12. 2027** as long as the test methods and/or factory production control requirements included in the STS, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the designated product certification body.

Detailed information about the scope of the product is given in the annex to this certificate.

Ljubljana, 15. 3. 2023

**Authorised signatory of the Certification body:**

Marjan Japelj, B. Sc.



**Scope of the certificate:**

| Product name                               | Characteristics | Value                            | Intended use                                                |
|--------------------------------------------|-----------------|----------------------------------|-------------------------------------------------------------|
| Double leaf steel fire door<br>IDRA 2B 120 | Fire resistance | EL <sub>2</sub> 120              | For fire/smoke compartmentation, for<br>use on escape routs |
|                                            | Smoke control   | S <sub>a</sub> /S <sub>200</sub> |                                                             |
|                                            | Escape routs    | Confirms                         |                                                             |

End of the Annex